

渥美最終処分場 一覧表

試料の種類		放流水(水処理槽)												最大値	最小値	平均値	基準値
		令和4年						令和5年									
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7	3/7				
採取年月日		9:35	11:12	10:59	13:10	10:40	11:03	13:26	11:11	11:22	11:30	11:19	11:02				
採取時刻																	
天候		雨	晴	晴	曇	晴	曇	晴	小雨	晴	晴	曇	晴				
気温	°C													-	-	-	-
水温	°C	19.0	19.3	21.5	24.5	28.1	27.8	23.0	21.7	17.9	12.0	12.1	12.1	28.1	12.0	19.9	-
水素イオン濃度	-	7.6	7.7	7.5	7.5	7.9	7.7	7.9	8.1	8.1	7.7	7.6	8.0	8.1	7.5	7.8	5.8-8.6
生物学的酸素要求量	mg/L	<0.5	<0.5	<0.5	0.5	<0.5	<0.5	0.5	0.5	0.7	<0.5	<0.5	0.5	0.7	0.5	0.5	60
化学的酸素要求量	mg/L	4.3	4.0	4.5	3.2	2.3	3.3	3.7	4.1	4.4	4.3	3.3	3.1	4.5	2.3	3.7	90
浮遊物質	mg/L	<1	<1	<1	<1	<1	<1	1	<1	<1	<1	<1	<1	1.0	1.0	1.0	60
窒素含有量	mg/L	3.2	3.6	6.4	6.1	7.4	3.2	4.7	4.5	2.1	4.8	4.8	5.5	7.4	2.1	4.7	120

試料の種類		地下水												最大値	最小値	平均値	
		令和4年						令和5年									
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7	3/7				
採取年月日		9:42	11:20	10:54	13:23	10:36	10:57	13:35	11:05	11:16	11:23	11:12	10:58				
採取時刻																	
天候		雨	晴	晴	曇	晴	曇	晴	小雨	晴	晴	曇	晴				
気温	°C													-	-	-	-
水温	°C													-	-	-	-
塩化物イオン	mg/L	17	18	20	19	32	25	29	21	23	28	22	24	32.0	17.0	23	
電気伝導率	mS/m	18	19	31	21	43	57	59	41	43	45	42	48	59.0	18.0	39	

試料の種類		周辺地下水												最大値	最小値	平均値	
		令和4年						令和5年									
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7	3/7				
採取年月日		9:51	11:24	10:42	13:28	10:26	10:45	12:44	10:55	11:04	11:13	11:00	10:47				
採取時刻																	
天候		雨	晴	晴	曇	晴	曇	晴	小雨	晴	晴	曇	晴				
気温	°C													-	-	-	-
水温	°C													-	-	-	-
塩化物イオン	mg/L	13	13	13	13	16	13	16	13	13	14	11	11	16.0	11.0	13	
電気伝導率	mS/m	22.0	22.0	22.0	21.0	22.0	22.0	23.0	22.0	23.0	22.0	20.0	23.0	23.0	20.0	22	