

第二東部最終処分場 一覧表

試料の種類		放流水(水処理槽)												最大値	最小値	平均値	基準値
		令和4年															
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7	3/7				
採取年月日		14:03	9:40	9:33	10:40	9:22	9:37	10:06	9:49	9:36	10:05	9:45	9:43				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	-
水温	℃	19.8	20.0	22.0	24.9	28	28	25.5	24.6	22.0	17.6	15.3	13.8	28.0	13.8	21.8	-
水素イオン濃度	-	7.1	7.3	7.2	7.4	7.5	7	7.5	7.6	6.3	6.7	6.8	7.0	7.6	6.3	7.1	5.8-8.6
生物学的酸素要求量	mg/L	3.3	3.8	5.4	0.9	0.7	<0.5	1.9	7.9	2.7	<0.5	<0.5	<0.5	7.9	0.7	3.3	60
化学的酸素要求量	mg/L	15	14	19	13	13	11	13	13	24	12	9.8	11	24.0	9.8	14.0	90
浮遊物質	mg/L	8	<1	<1	1	<1	<1	3	3	1	6	9	<1	9.0	1.0	4.4	60
窒素含有量	mg/L	31	36	38	41	41	29	34	37	39	37	36	39	41.0	29.0	37	120

試料の種類		地下水(上流)												最大値	最小値	平均値	
		令和4年															
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7	3/7				
採取年月日		14:14	9:31	9:39	10:50	9:26	9:43	10:14	9:54	9:41	10:04	9:52	9:47				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	-
水温	℃													-	-	-	-
塩化物イオン	mg/L	42	41	43	97	57	45	20	18	21	22	17	18	97.0	17.0	37	
電気伝導率	mS/m	57	56	56.0	57.0	56	57	55.0	56	56	56	52	57.0	57.0	52.0	55.9	

試料の種類		地下水(下流)												最大値	最小値	平均値	
		令和4年															
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7	3/7				
採取年月日		14:23	9:47	9:45	10:57	9:32	9:49	10:22	10:00	9:47	10:16	9:58	9:52				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	-
水温	℃													-	-	-	-
塩化物イオン	mg/L	20	22	23	32	28	18	14	18	24	26	20	20	32.0	14.0	22	
電気伝導率	mS/m	84.0	84.0	81.0	79.0	78	71	84	80	77	77	71	79	84.0	71.0	78.8	