

田原市一般廃棄物最終処分場(リサイクルセンター併設) 一覧表

試料の種類		放流水(水処理槽)											最大値	最小値	平均値	基準値	
		令和4年															
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7					3/7
採取年月日		13:17	9:22	9:24	10:19	9:14	9:28	9:51	9::38	9:27	9:48	9:36	9:33				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	-
水温	℃	21.0	20.1	23.2	25.9	28.8	29.7	23.4	19.8	15.0	9.4	7.8	9.7	29.7	7.8	19.5	-
水素イオン濃度	-	7.7	8.2	7.8	7.9	8	8	8	7.8	7.6	7.7	7.8	7.7	8.2	7.6	7.9	5.8-8.6
生物学的酸素要求量	mg/L	1.4	<0.5	<0.5	0.7	<0.5	<0.5	0.6	0.7	0.9	<0.5	<0.5	1.0	1.4	0.6	0.9	60
化学的酸素要求量	mg/L	55	36	42	52	46	48	38	45	43	47	49	52	55.0	36.0	46.1	90
浮遊物質	mg/L	3	<1	<1	<1	<1	<1	1	<1	<1	<1	<1	1	3.0	1.0	1.7	60
窒素含有量	mg/L	94	69	93	110	97	85	64	93	100	94	88	87	110.0	64.0	90	120

試料の種類		地下水(上流)											最大値	最小値	平均値		
		令和4年															
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7				3/7	
採取年月日		13:32	9:15	9:09	9:40	9:01	9:14	9:26	9:25	9:15	9:33	9:23	9:03				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	
水温	℃													-	-	-	
塩化物イオン	mg/L	53	67	67	63	80	71	78	62	72	68	57	54	80.0	53.0	66	
電気伝導率	mS/m	61	71	71.0	70.0	67	67	66.0	63	64	60	65	60.0	71.0	60.0	65.4	

試料の種類		地下水(下流)											最大値	最小値	平均値		
		令和4年															
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7				3/7	
採取年月日		13:40	9:09	9:16	9:50	9:07	9:21	9:32	9:31	9:20	9:40	9:30	9:27				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	
水温	℃													-	-	-	
塩化物イオン	mg/L	30	30	28	27	26	25	31	39	39	57	49	53	57.0	25.0	36	
電気伝導率	mS/m	65.0	68.0	70.0	70.0	70	67	74	82	80	85	78	81	85.0	65.0	74.2	