

田原市埋立処分場(破碎施設併設) 一覧表

試料の種類		放流水(水処理槽)											最大値	最小値	平均値	基準値	
		令和4年									令和5年						
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7					3/7
採取年月日		11:23	8:51	8:53	8:55	8:47	8:57	9:00	9:10	8:57	9:09	8:58	8:47				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	-
水温	℃	19.3	22.0	22.0	26.7	28.8	27.6	19.0	17.5	12.5	8.5	7.8	9.0	28.8	7.8	18.4	-
水素イオン濃度	-	7.8	8.1	7.7	8.1	8	8.1	7.8	8.1	7.9	8.0	7.7	7.6	8.1	7.6	7.9	5.8-8.6
生物学的酸素要求量	mg/L	1.3	7.8	<0.5	0.9	0.5	0.6	11	0.6	48	5	31	14.0	48.0	0.5	11.0	60
化学的酸素要求量	mg/L	11	16	9.9	14	14	10	4.2	5.8	7.4	8.8	6.9	8.1	16.0	4.2	9.7	90
浮遊物質	mg/L	<1	<1	<1	<1	<1	<1	1	<1	<1	<1	<1	<1	1.0	1.0	1.0	60
窒素含有量	mg/L	25	41	41	30	27	15	51	55	47	43	45	50	55.0	15.0	39	120

試料の種類		地下水(佐久間宅)											最大値	最小値	平均値		
		令和4年									令和5年						
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7				3/7	
採取年月日		11:37	8:57	9:00	9:11	8:54	9:04	9:09	9:18	9:09	9:25	9:12	8:55				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	-
水温	℃													-	-	-	-
塩化物イオン	mg/L	18	15	17	17	23	20	20	17	17	20	15	13	23.0	13.0	18	
電気伝導率	mS/m	26	23	23.0	24.0	23	23	23.0	23	23	23	28	24.0	28.0	23.0	23.8	

試料の種類		地下水(水道課)											最大値	最小値	平均値		
		令和4年									令和5年						
		4/26	5/10	6/7	7/5	8/2	9/6	10/11	11/1	12/6	1/10	2/7				3/7	
採取年月日		11:45	8:41	8:41	8:45	8:39	8:47	8:46	9:00	8:48	8:57	8:46	8:37				
採取時刻																	
天候		雨	曇	晴	雨	晴	晴	晴	雨	晴	晴	曇	晴				
気温	℃													-	-	-	-
水温	℃													-	-	-	-
塩化物イオン	mg/L	19	18	18	18	23	20	21	18	18	19	15	15	23.0	15.0	19	
電気伝導率	mS/m	23	23	23.0	23.0	24	24	24.0	23	23	23	21	23.0	24.0	21.0	23.1	