

渥美最終処分場 一覧表

試料の種類		放流水(水処理槽)											最大値	最小値	平均値	基準値	
		令和5年															
		4/25	5/9	6/6	7/4	8/1	9/5	10/10	11/7	12/5	1/9	2/13					3/5
採取年月日		11:32	11:02	11:26	13:11	11:46	11:11	13:20	11:31	10:58	11:29	11:39	11:25				
採取時刻		曇り	晴れ	曇り	晴れ	晴れ	雨	晴れ	曇り	曇り	晴れ	晴れ	雨				
天候																	
気温	°C	14.5	18.1	21.3	31.0	31.8	29.5	24.8	18.9	9.8	8.2	13.0	6.5	31.8	6.5	19.0	-
水温	°C	16.8	19.2	21.8	25.0	26.8	21.6	23.0	20.0	15.8	12.9	14.0	12.5	26.8	12.5	19.1	-
水素イオン濃度	-	7.9	7.9	7.9	7.7	7.4	7.7	8.0	7.9	8.0	8.0	8.0	8.3	8.3	7.4	7.9	5.8-8.6
生物学的酸素要求量	mg/L	<0.5	<0.5	<0.5	<0.5	<0.5	0.7	<0.5	0.9	<0.5	<0.5	<0.5	0.7	0.9	<0.5	<0.5	60
化学的酸素要求量	mg/L	3.0	3.4	2.8	3.8	3.5	4.0	5.1	4.8	4.0	4.2	3.7	3.4	5.1	2.8	3.8	90
浮遊物質	mg/L	1	<1	<1	<1	2	<1	<1	<1	<1	<1	<1	<1	2.0	<1	<1	60
窒素含有量	mg/L	4.5	5.6	4.0	4.6	5.0	2.4	2.9	3.4	3.6	3.5	3.1	3.8	5.6	2.4	3.9	120

試料の種類		地下水											最大値	最小値	平均値		
		令和5年															
		4/25	5/9	6/6	7/4	8/1	9/5	10/10	11/7	12/5	1/9	2/13				3/5	
採取年月日		11:27	10:56	11:20	13:22	11:42	11:18	13:11	11:21	10:54	11:24	11:46	11:06				
採取時刻		曇り	晴れ	曇り	晴れ	晴れ	雨	晴れ	曇り	曇り	晴れ	晴れ	雨				
天候																	
気温	°C	14.5	18.1	21.3	31.0	31.8	29.5	24.8	18.9	9.8	8.2	13.0	6.5	31.8	6.5	19.0	
水温	°C	14.0	17.7	19.0	21.0	20.8	27.0	21.0	18.5	15.8	13.2	9.0	13.2	27.0	9.0	17.5	
塩化物イオン	mg/L	22	20	46	22	23	23	19	21	21	23	26	35	46.0	19.0	25	
電気伝導率	mS/m	29	19	69	26	32	24	16	24	24	28	32	57	69.0	16.0	32	

試料の種類		周辺地下水											最大値	最小値	平均値		
		令和5年															
		4/25	5/9	6/6	7/4	8/1	9/5	10/10	11/7	12/5	1/9	2/13				3/5	
採取年月日		11:15	10:44	11:10	13:28	11:57	11:00	12:57	11:11	10:43	11:11	11:53	11:21				
採取時刻		曇り	晴れ	曇り	晴れ	晴れ	曇り	晴れ	曇り	曇り	晴れ	晴れ	雨				
天候																	
気温	°C	14.5	18.1	21.3	31.0	31.8	29.5	24.8	18.9	9.8	8.2	14.0	6.5	31.8	6.5	19.0	
水温	°C	14.2	18.1	19.3	18.5	25.7	18.9	17.9	16.5	12.8	16.5	16.0	18.3	25.7	12.8	17.7	
塩化物イオン	mg/L	13	13	15	15	16	16	16	15	14	14	15	16	16.0	13.0	15	
電気伝導率	mS/m	20	19	23	22	22	22	22	21	22	22	22	22	23.0	19.0	22	